

June 09, 2022

Weed Union Elementary School District
Jon Ray
575 White Avenue 96094
Weed, CA 96094

SERVICE:
Lead Inspection & Report

DATE AND TIME:
June 07, 2022 | 07:00 AM

LOCATION | AREA:
575 White Avenue, Weed CA 96094

CONSULTANT:
Dominick Sager

Dear Mr. Ray

This report is in regards to lead wipe clearance sampling conducted at the above listed site. Lead clearance wipes were collected and analyzed utilizing the SW 846 3050B*/7000 method.

RESULTS:

Based on the results of the samples collected, the impacted area(s) have been cleared for general access, without any health or safety concerns in regard to the exposure of lead hazardous dust.

SAMPLING & ANALYSIS:

During the visual inspection, the consultant discovered no visible dust, debris or any other impairment prohibiting the performance of the lead wipe testing. The clearance levels are below the EPA's lead wipe floor clearance level of 10 µg/ft².

Included at the end of the clearance letter, you will find a table containing the analytical results for the various areas sampled today.

REGASGROUP
ENVIRONMENTAL CONSULTANTS

If you require additional information regarding this report or if I can be of further assistance, please feel free to contact me directly.

Reviewed and Submitted by:



Dominick Sager
Senior Consultant

RegasGroup

Environmental Consultants

CAC #13-5082

CDPH #24356

NV #IM1131

Mycometer

MMA-0226-US | MMS-1258-US | BQS-0118-US



MicroTest Laboratories Inc. | AIHA ELPAT #160934
 3110 Gold Canal Dr. Ste. A. Rancho Cordova, CA 95670
 PH 916.567.9808 | FX 916.404.0302
 www.microtestlabsinc.com | service@microtestlabsinc.com

Project ID
MT012220302

CLIENT INFORMATION

Company RegasGroup
Name Dominick Sager
Address 705 E. Bidwell St. 2-244
 Folsom CA, 95630
Phone (916) 235 - 3110
Email service@regasgroup

SAMPLE

Date Tuesday, June 07, 2022
Time 7:00 AM

MicroTest

Laboratories

Analytical Data

JOB SITE INFORMATION

Sampler Dominick Sager
Project Weed Elementary School Property
Address 575 White Avenue
 Weed, CA 96094

LEAD by Flame AAS NIOSH 7082M

Sample ID	Accession Number	Location	Area (inches)	Matrix	Results	Units	Reporting Limit	Notes/Comments
575-1LCW	20302-1	Boy's Restroom Containment Floor, Center Area	12x12	Wipe	<10	µg/ft²	10 µg/ft²	
575-2LCW	20302-2	Girl's Restroom Containment Floor, Center Area	12x12	Wipe	<10	µg/ft²	10 µg/ft²	
575-3LCW	20302-3	Field Blank	12x12	Wipe	<10	µg/ft²	10 µg/ft²	

Report
Date Thursday, June 09, 2022

Samples Received: 3
Samples Analyzed: 3

Analyst: Ry Jensen

Authorized Signatory:

Kelly Favero - Lab Manager

This report applies to the standards and procedures indicated and to the specific samples analyzed. Samples have NOT been corrected for blank values. EPA Method 7000B & EPA Method 7420=EPA 600R/R93/200 Preparation Modified & EPA 7000B & EPA 7420 Analysis Modified.



RegasGroup Environmental Consultants
 705 E. Bidwell St., Suite 2-244, Folsom CA 95630
 PH 916.235.3110 | FX 916.404.5170
 www.RegasGroup.com | Service@RegasGroup.com

for office use only

RG Order
Client ID
Client PO
Project ID

MT012220302

CLIENT INFORMATION

Company Weed Union Elementary School District
Name Jon Ray
Address 575 White Avenue
 Weed CA, 96094
Phone (530) 938 - 2715
Email Need This

SAMPLE

Date Tuesday, June 07, 2022
Time 10:15 AM

REGASGROUP

Chain-Of-Custody

JOB SITE INFORMATION

Site Weed Elementary School Property
Address 575 White Avenue
 Weed, CA 96094
Unit
Claim# PO: 210216
Job # 42136
Chain # 1

Analysis: Lead Clearance Wipe
Turn Around Time: Same Day

Sample ID:	Area	Sample Location	Description
575-1LCW	12x12	Boy's Restroom Containment Floor, Center Area	Lead Clearance Wipe
575-2LCW	12x12	Girl's Restroom Containment Floor, Center Area	Lead Clearance Wipe
575-3LCW		Field Blank	Field Blank

California Dept. of Public Health
www.2.epa.gov/lead



Sampler: Dominick Sager

Analyst: _____

Total Number of Samples 3

Relinquished by (Client)	Date/Time

Relinquished by (Tech)	Date/Time
	06/07/2022 07:00 AM

Received by (Tech)	Date/Time

Received by (Lab)	Date/Time
	06/09/2022 10:49 AM